



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

July 31, 2013

Ed Minhinnick
Asphalt Services of Ohio
4579 Poth Road
Whitehall, Ohio 43213

**RE: Construction Storm Water Inspection at Main Office / Franklin County
Permit Number: 4GC04132 *AG**

Dear Mr. Minhinnick:

This letter is written regarding a storm water inspection conducted by Sam Marotta and Rachel Bellis of the Ohio EPA at Main Office located at 4579 Poth Road on July 16, 2013. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

Sediment and Erosion Control:

- Please ensure all storm water from the disturbed areas maintain positive drainage to the impoundments intended for sediment control.
- Be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at harry.kallipolitis@epa.state.oh.us.

Sincerely

Harry Kallipolitis
Storm Water Coordinator
Ohio EPA
Division of Surface Water

c: Jeff Bohne, Water Quality Supervisor, DSW / CDO