



John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

Re: Putnam County  
State Route 65 Williamstown Road  
Intersection Improvements  
Construction Storm Water  
Facility ID No. 2GC03236

August 5, 2013

The Honorable Dean Meyer  
Mayor of the Village of Ottawa  
136 North Oak Street  
Ottawa, Ohio 45875

Mr. Neal Orsbon  
Shelly Company  
1700 Fostoria Avenue #200  
Findlay, Ohio 45840

Dear Mayor Meyer and Mr. Orsbon:

On July 17, 2013, Tom Wilkins and Zach Titkemeier inspected the State Route 65 Williamstown Road Intersection Improvements at the intersection of State Route 65 and Williamstown Road, Ottawa. The purpose of the visit was to evaluate compliance of the site with the National Pollutant Discharge Elimination System (NPDES) permit for storm water discharges associated with construction activity. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111.

It appears that construction activities at the State Route 65 Williamstown Road Intersection Improvements are complete. A repaved intersection and roadway was present. A Notice of Termination (NOT) must be filed to relieve you of the obligation to comply with this general permit. An NOT may be filed if one or more of the following conditions have been met:

- Final stabilization has been established on all areas of the site for which the permittee is responsible. Final stabilization means that all soil disturbing activities at the site are complete and a uniform perennial vegetative cover of at least 70% density has been established over the entire site. All temporary erosion and sediment control measures have been removed, properly disposed of, and all trapped sediment has been permanently stabilized; or

Mayor Dean Meyer and Mr. Neal Orsbon  
August 5, 2013  
Page Two

- Another operator(s) has assumed control over all areas of the site that have not been fully stabilized.


While construction activities were complete, it was not apparent what post construction storm water management controls had been installed. The permit requires that post-construction Best Management Practices (BMPs) are installed during construction to control pollutants in the storm water discharges that will occur after construction has concluded. Such practices may include, but are not limited to: water quality swales; bioretention areas; and certain types of proprietary devices. Please send a written response describing what post construction storm water management practices are being/will be implemented at the site within 10 days of the date on this letter. Your reply should include the type(s) of practices, the basis for its design, and installation dates. When all permit conditions have been met, please file the NOT form. The NOT form and instructions can be found on our website:

<http://www.epa.ohio.gov/dsw/storm/stormform.aspx>

NOTs must be mailed to Ohio EPA's Central Office within 45 days of when the above criteria are met.

If there are any questions, please contact me at 419-373-3009.

Sincerely,



Lynette Hablitzel, P.E.  
Division of Surface Water  
Storm Water Program

/jlm

ec: Tracking