



John E. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Walk, Director

July 31, 2013

Doug Schwartz
Columbus City Schools
Department of Facilities
889 East 17th Avenue
Columbus, OH 43215

Re: Cedarwood Alternative Elementary School, Franklin County

Dear Mr. Schwartz:

This letter is written regarding the storm water inspection that I conducted on July 3, 2013, at the Cedarwood Alternative Elementary School located at 775 Bartfield Drive, in Columbus. It appears that construction is nearly complete. I understand that these construction activities are covered under the General Storm Water Permit Associated with Construction Activities. Based on the site inspection and the General Storm Water Permit, the following items must be addressed:

Sediment and Erosion Control:

- Please stabilize all barren areas within seven days of final grade. Most of the site appeared to be at final grade.

If you have any questions regarding this letter or my inspection, please do not hesitate to contact me at our Central District Office at 614-728-3851 or email at greg.sanders@epa.state.oh.us.

Sincerely,

Gregory L. Sanders
Environmental Specialist
Division of Surface Water
Central District Office

c: Tom Andry, Smoot Elford

GS/stw Cedarwood Alternative ES, July 3, 2013