



Bob Taft, Governor
Mary Taylor, Lt. Governor
John J. Malley, Director

July 30, 2013

Bill Heifner
Riener Construction
2164 City Gate Drive
Columbus, Ohio 43219

Re: Construction Storm Water Inspection at Chesrown Chevrolet, Buick & GMC/ Delaware County. Permit #: 4GCO00099*AG

Dear Mr. Heifner:

This letter is written regarding a storm water inspection I conducted at Chesrown Chevrolet, Buick & GMC located at the intersection of Hull Drive and Route 23 on July 11, 2013. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

Sediment and Erosion Control:

- The northernmost basin has been installed. A modified outlet structure incorporating a temporary riser was also noted during the inspection. Please ensure the riser is effectively sealed to the outlet structure. Risers tend to float up during large precipitation events, jeopardizing the seal and the associated sediment storage.
- The southernmost basin is currently under construction. I was informed by the on-site contractor that the completion of this basin is expected by July 20, 2013. Please ensure positive drainage to all basins intended for sediment control. I noted the installation of a diversion to the northern basin. A second diversion in conjunction with the southernmost basin is expected to ensure positive flow to the basin during all phases of construction.
- Be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at harry.kallipolitis@epa.state.oh.us.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office