



John R. Kasich, Governor
 Mary Taylor, Lt. Governor
 Scott J. Nally, Director

August 6, 2013

Re: Tuscarawas County
 Baltic WWTP
 Self-Monitoring Report Violations
 Ohio EPA Permit 0PB00067*HD

Mayor and Council
 Baltic WWTP
 P.O. Box 320
 Baltic, OH 43804

We have received your self-monitoring reports covering the months of May and June 2013 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

May 2013:

Station	Type	Date	Reporting Code	Parameter	Limit Type	Permit Limit	Reported Value
001	Limit	5/1/2013	00665	Phosphorus, Total (P)	Monthly Conc.	1.0	7.05
001	Limit	5/1/2013	00665	Phosphorus, Total (P)	Monthly Load	0.379	1.68111
001	Freq	5/1/2013	50060	Chlorine, Total Residual	1/Day	1	0
001	Freq	5/2/2013	50060	Chlorine, Total Residual	1/Day	1	0
001	Freq	5/3/2013	50060	Chlorine, Total Residual	1/Day	1	0
001	Freq	5/4/2013	50060	Chlorine, Total Residual	1/Day	1	0
001	Freq	5/5/2013	50060	Chlorine, Total Residual	1/Day	1	0
001	Freq	5/6/2013	50060	Chlorine, Total Residual	1/Day	1	0
001	Freq	5/31/2013	50060	Chlorine, Total Residual	1/Day	1	0
001	Freq	5/25/2013	50060	Chlorine, Total Residual	1/Day	1	0
001	Freq	5/26/2013	50060	Chlorine, Total Residual	1/Day	1	0
001	Freq	5/27/2013	50060	Chlorine, Total Residual	1/Day	1	0
001	Freq	5/28/2013	50060	Chlorine, Total Residual	1/Day	1	0
001	Freq	5/29/2013	50060	Chlorine, Total Residual	1/Day	1	0
001	Freq	5/30/2013	50060	Chlorine, Total Residual	1/Day	1	0
001	Freq	5/19/2013	50060	Chlorine, Total Residual	1/Day	1	0
001	Freq	5/20/2013	50060	Chlorine, Total Residual	1/Day	1	0
001	Freq	5/21/2013	50060	Chlorine, Total Residual	1/Day	1	0

Station	Type	Date	Reporting Code	Parameter	Limit Type	Permit Limit	Reported Value
001	Freq	5/22/2013	50060	Chlorine, Total Residual	1/Day	1	0
001	Freq	5/23/2013	50060	Chlorine, Total Residual	1/Day	1	0
001	Freq	5/24/2013	50060	Chlorine, Total Residual	1/Day	1	0
001	Freq	5/13/2013	50060	Chlorine, Total Residual	1/Day	1	0
001	Freq	5/14/2013	50060	Chlorine, Total Residual	1/Day	1	0
001	Freq	5/15/2013	50060	Chlorine, Total Residual	1/Day	1	0
001	Freq	5/16/2013	50060	Chlorine, Total Residual	1/Day	1	0
001	Freq	5/17/2013	50060	Chlorine, Total Residual	1/Day	1	0
001	Freq	5/18/2013	50060	Chlorine, Total Residual	1/Day	1	0
001	Freq	5/7/2013	50060	Chlorine, Total Residual	1/Day	1	0
001	Freq	5/8/2013	50060	Chlorine, Total Residual	1/Day	1	0
001	Freq	5/9/2013	50060	Chlorine, Total Residual	1/Day	1	0
001	Freq	5/10/2013	50060	Chlorine, Total Residual	1/Day	1	0
001	Freq	5/11/2013	50060	Chlorine, Total Residual	1/Day	1	0
001	Freq	5/12/2013	50060	Chlorine, Total Residual	1/Day	1	0

June 2013:

Station	Type	Date	Reporting Code	Parameter	Limit Type	Permit Limit	Reported Value
001	Limit	6/1/2013	00665	Phosphorus, Total (P)	Monthly Conc.	1.0	2.73
001	Limit	6/1/2013	00665	Phosphorus, Total (P)	Monthly Load	0.379	.99197
601	Code	6/21/2013	50047	Flow, Peak Rate			AB
601	Code	6/22/2013	50047	Flow, Peak Rate			AB
601	Code	6/23/2013	50047	Flow, Peak Rate			AB
601	Code	6/24/2013	50047	Flow, Peak Rate			AB

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Please inform this office, in writing, within ten days of receipt of this notification as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions.

The Ohio EPA strongly encourages pollution prevention as the preferred approach for waste management. The first priority of pollution prevention is to eliminate the generation of wastes and pollutants at the source (source reduction). For those wastes or pollutants that are generated, the second priority is to recycle or reuse them in an environmentally sound manner. You can benefit economically, help preserve the

environment, and improve your public image by implementing pollution prevention programs. For more information about pollution prevention, including fact sheets and U.S. EPA's Facility Pollution Prevention Guide, (EPA/600/R-92/088), you may contact the Ohio EPA Pollution Prevention Section at (614) 644-3469 or me for additional information.

If there are any questions, please contact this office.

Sincerely,



Timothy A. Fulks
District Representative
Division of Surface Water

TF/dh