



John R. Kasich, Governor  
 Mary Taylor, Lt. Governor  
 Scott J. Nally, Director

August 6, 2013

Re: Athens County  
 Albany WWTP  
 Self-Monitoring Report Violations  
 Ohio EPA Permit 0PB00087\*CD

Mayor and Council  
 Albany WWTP  
 5153 Alton Street  
 Albany, OH 45710

We have received your self-monitoring report covering the month of June 2013 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Station	Type	Date	Reporting Code	Parameter	Limit Type	Permit Limit	Reported Value
001	Limit	6/1/13	00610	Nitrogen, Ammonia (NH3)	Monthly Conc.	1.0	1.8425
001	Limit	6/1/13	00610	Nitrogen, Ammonia (NH3)	Monthly Load	0.50	.56183
001	Limit	6/8/13	00610	Nitrogen, Ammonia (NH3)	Weekly Conc.	1.5	2.365
001	Limit	6/8/13	00610	Nitrogen, Ammonia (NH3)	Weekly Load	0.74	1.19617
001	Limit	6/22/13	00610	Nitrogen, Ammonia (NH3)	Weekly Conc.	1.5	4.32
001	Limit	6/22/13	00610	Nitrogen, Ammonia (NH3)	Weekly Load	0.74	.87354

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

We have reviewed your report addressing the reasons for the above violations and the actions being taken to prevent further occurrences. Hopefully, these actions will prevent any recurrence so that enforcement action will not be required. No additional information is requested at this time.

The Ohio EPA strongly encourages pollution prevention as the preferred approach for waste management. The first priority of pollution prevention is to eliminate the generation of wastes and pollutants at the source (source reduction). For those wastes or pollutants that are generated, the second priority is to recycle or reuse them in an environmentally sound manner. You can benefit economically, help preserve the environment, and improve your public image by implementing pollution prevention

programs. For more information about pollution prevention, including fact sheets and U.S. EPA's Facility Pollution Prevention Guide, (EPA/600/R-92/088), you may contact the Ohio EPA Pollution Prevention Section at (614) 644-3469 or me for additional information.

If there are any questions, please contact this office.

Sincerely,

A handwritten signature in blue ink that reads "Nicholas G. Hammer". The signature is written in a cursive style.

Nicholas G. Hammer  
Environmental Specialist  
Permits and Compliance Section  
Division of Surface Water

NH/dh