



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

August 8, 2013

Re: Tuscarawas County
Pine Lane Farm
Storm Water Construction Activity
Permit OGC01979*AG

Mr. Bruce Beachy
Pine Lane Farm
9924 Lower Trail Road
Dundee, OH 44624

Dear Mr. Beachy:

On July 23, 2013, I visited the site located on Lower Trail Road that has a construction storm water permit with the Ohio EPA. The purpose of my inspection was to determine the compliance of this site with the National Pollutant Discharge Elimination System (NPDES) permit for discharges of storm water associated with construction activity. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111.

No violations of the terms and conditions of the permit were discovered. Please continue to implement permit requirements as construction continues.

As a reminder, the permit requires that any area that will lie dormant for more than 21 days, but less than a year be stabilized within 7 days of the most recent disturbance.

If there are any questions, please contact Aaron Wolfe at (740) 380-5277 or myself at (740) 380-5447.

Sincerely,

A handwritten signature in blue ink, which appears to read "Clinton Kuenzli".

Clinton Kuenzli
Storm Water Section
Division of Surface Water

CDK/dh