



John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

August 6, 2013

Larry Mayer  
Ohio Eastern Star Health Care Center  
1451 Gambier Road  
Mount Vernon, OH 43050

**Re: Notice of Termination Inspection at Ohio Eastern Star Health Center / Knox County. Permit Number: 4GC03857\*AG**

Dear Mr. Mayer,

This letter is written in follow up to a construction storm water inspection by Jerome Hoke, of the Ohio EPA, at Ohio Eastern Star Health Center located at 1451 Gambier Road on July 22, 2013. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities.

It appeared during the inspection that construction activity has been completed for this site. A Notice of Termination form is required provided the following items are addressed:

- All areas must be protected from erosion measured by a minimum vegetative density of 70 percent for all disturbed areas.
- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction mandates can be found at: <http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx>. Please submit to my attention (email preferred at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us)) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria with your submittal.
- If the vegetative requirements above are met please submit your Notice of Termination (NOT) concurrent with your submittal of the post construction verification. The NOT form can be found at: [http://www.epa.state.oh.us/portals/35/documents/NOT\\_app\\_fis.pdf](http://www.epa.state.oh.us/portals/35/documents/NOT_app_fis.pdf)

Larry Mayer  
Ohio Eastern Star Health Care Center  
Page 2

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844.

Sincerely,

A handwritten signature in black ink, appearing to read "Harry Kallipolitis". The signature is written in a cursive style with a long, sweeping underline.

Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office

HK/nsm Ohio Eastern Star Health Center 7-22-13