



John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott A. Rahl, Director

August 6, 2013

Cleve Igoe  
Auto Tool Facility  
8150 Business Way  
Plain City, OH 43064

**Re: Construction Storm Water Inspection at Auto Tool Facility/ Union County  
Permit Number: 4GC04021\*AG**

Dear Mr. Igoe:

This letter is written regarding a storm water inspection conducted by Elizabeth Pleta and Rachel Bellis of the Ohio EPA at Auto Tool Facility located on Corporate Boulevard (40.128163, -83.194165) on Jul 22, 2013. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

### **Sediment and Erosion Control**

- The sediment controls implemented on this site will require maintenance or reinstallation to ensure a proper functioning condition (See Figures 1 & 2). The General Permit states that all sediment controls will be inspected and maintained every seven days or within 24 hours of a precipitation event equal to or greater than 0.5 inches. A log of inspection must be maintained on site for the agency to review.
- During the inspection, it was noted that a sediment control outlet structure was not installed on the east or north ponds (See Figures 3 & 4). This results in the elimination of all effective sediment storage. These impoundments must incorporate a temporary riser or skimmer. The riser must be set to an elevation to accommodate the required storage of 67 cubic yards per acre of drainage for the dewatering zone and thirty seven (37) cubic yards per acre of disturbance for the sediment settling zone. Please ensure this is implemented within seven (7) days of receiving this letter. Please refer to the following link for assistance: <http://www.dnr.state.oh.us/water/rainwater/default/tabid/9186/default.aspx>

### Concrete Washout

- Concrete activities were noted on site (See Figure 5) a washout containment area must be established to ensure compliance with the Ohio EPA's General Storm Water Permit.

### Barren Areas

- Be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us).

Sincerely,




Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office




**Figure 1 Overburdened silt fence on east side of site, adjacent to Corporate Boulevard.**




**Figure 2 Silt fence requiring maintenance on east side of site, adjacent to Corporate Boulevard.**



**Figure 3 North pond requiring temporary riser or skimmer.**



**Figure 4 East pond, adjacent to Corporate Boulevard, requiring temporary riser or skimmer.**



**Figure 5 Evidence of concrete activities, requiring a designated concrete washout area with proper containment.**