



John R. Kasich, Governor
Mary Taft, Lt. Governor
Scott J. Nally, Director

August 6, 2013

Rich Irelan
Dublin Building Systems Corporations Incorporated
PO Box 370
Dublin, OH 43017

Re: **Storm Water Inspection at Silver Threads / Union County**
Permit #: 4GC04131*AG

Dear Mr. Irelan:

This letter is written in follow-up to a construction storm water inspection by Rachel Bellis and Elizabeth Pleta of the Ohio EPA, at Silver Threads located at 7710 Corporate Boulevard on July 22, 2013. The purpose of the inspection was to evaluate compliance with Ohio EPA's General Storm Water Permit Associated with Construction Activities. During the inspection, we noted the following:

Sediment and Erosion Controls

- Be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days.
- The sediment and erosion controls at this site are currently functioning properly. Please continue to monitor and ensure continued compliance with the General Storm Water Permit Associated with Construction Activities.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844. Follow up inspections will be conducted to ensure the conditions of the General Permit are continuing to be met.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

HK/nsm Silver Threads 7-22-2013