



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

August 12, 2013

Mr. Chris McCoy
McCoy Architects LLC
380 South Mill Street #204
Lexington, Kentucky 40508

**RE: Islamic Society of Greater Dayton; NPDES Permit # 1GC04025*AG
Construction Site Inspection**

Dear Mr. McCoy:

On Thursday, August 1, 2013, I inspected the Islamic Society of Greater Dayton located in Sugarcreek Township, Ohio, to determine compliance with its NPDES construction site storm water discharge permit. I walked the property, and met with Nayeem Choudury of Planex Inc.

In our email correspondences at the beginning of June, we discussed the transfer of the site's construction permit to Mr. Choudury. According to our records, this transfer never took place. I spoke with Mr. Choudury regarding this issue. He confirmed that he had not mailed in the transfer paperwork. Because of this, Ohio EPA still considers McCoy Architects to be the permittee for this project. I provided Mr. Choudury with a copy of the transfer form that you emailed to me, and the mailing address to where the paperwork should be mailed.

During my visit, I noticed that the sediment basin located in the southeast corner of the site, did not have an outlet structure. There is a large cut in the basin's side wall, which I assume is where the outlet structure will be placed. I asked Mr. Choudury about the sediment basin and he explained that the outlet structure was on order and should arrive in approximately one week. However, upon further research, I became aware that the observed cut in the basin wall has been there for over a year, as shown in the attached photos. The site is therefore in violation of Part III.G.2.d of its permit, which addresses sediment control practices at construction sites. Once the outlet structure has been installed, and the basin is capable of retaining eroded sediments carried to it in stormwater runoff, the site will be back in compliance.

Please send to Mr. Chris Cotton, who will be taking over compliance in regards to this site beginning August 19, 2013, photos showing the completed installation of the outlet structure.

August 12, 2013

Page 2

As a reminder, compliance with the permit must be upheld until construction is complete, and all areas of the site have been permanently stabilized with vegetation or other ground cover. Once final stabilization is achieved, the construction permit must be terminated by completing the one page "Notice of Termination" (NOT) form found at http://www.epa.ohio.gov/Portals/35/permits/General_NOT.pdf and sending it to the following address:

Ohio Environmental Protection Agency
General Permit Program
P.O. Box 1049
Columbus, Ohio 43216-1049

If you have questions regarding this letter you can contact me at (937) 204-1003, or via email at eric.damian@epa.ohio.gov or Chris Cotton at (937) 285-6442 and chris.cotton@epa.ohio.gov.

Sincerely,



Eric Damian
Storm Water Group
Division of Surface Water

ED/tb

cc: Nayeem Choudury, Planex Inc. - planex_gc@yahoo.com

Enclosure: Inspection Form
Inspection Photos

Ohio EPA DSW Storm Water Section, Construction Site Visit Information Form

Inspector initials: ESD Visit date: 8/1/13 Permit # 1GC04025*AG

Site Name: Islamic Society of Greater Dayton

Site Address: 731 South Alpha Bellbrook Rd

People Contacted On Site: Nayeem Choudury

Phone: 513-464-3360 E-mail: planex-gc@yahoo.com

1. Did you see the following on site?

ITEM	YES	NO	Not Requested	Comments
NOI			✓	
Coverage Letter			✓	
SWP3	✓			
Inspection Records			✓	
Contractor & Subs signature document			✓	

2. Acreage Disturbed: 8.5

3. Site Status: Clearing/grubbing Rough Grading Storm sewers in
 Streets in Utilities installed Final Grade Final stabilization

4. Are BMPs needed: outlet for sediment basin

5. Are BMPs effective? All Some None No BMPs
 Explain: silt fence good, no outlet structure on sed. basin

6. What post construction controls are shown on the SWP3? sediment basin

7. Were Photos taken & saved? yes 8. Was an NOV issued? yes

Additional notes/comments:

- outlet structure on order, to arrive w/in one week according to Nayeem
- Nayeem given transfer form from McCoy Architects
- mailing address to be e-mailed to Nayeem





08/01/2013 13:45



07/02/2012 13:51