



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

August 9, 2013

Mountain Agency LLC
829 Eastgate South Drive
Cincinnati, OH 45245

**RE: Jeff Wyler Chevrolet of Springfield; NPDES Permit #1GC04313*AG;
Compliance Inspection Findings**

To Whom It May Concern:

On Thursday, August 8, 2013, I inspected the Jeff Wyler Chevrolet site in Springfield, Ohio, to determine compliance with the site's NPDES construction site storm water discharge permit. I spoke with a representative from the Jeff Wyler dealership during the inspection.

Based on my observations, there were no obvious violations of the project's storm water discharge permit. I did not review the sediment control inspection logs or the site's storm water pollution prevention plan before my inspection, but records of inspections of the erosion control BMPs are required to be kept.

As a reminder, please note that when construction is complete, and all areas of the site have been permanently stabilized with vegetation or other ground cover, the construction permit must be terminated. A one page "notice of termination" (NOT) form found at http://www.epa.ohio.gov/Portals/35/permits/General_NOT.pdf must be completed and sent to the following address:

Ohio Environmental Protection Agency
General Permit Program
PO Box 1049
Columbus, OH 43216-1049

No response to this letter is needed.

Jeff Wyler Chevrolet of Springfield
August 9, 2013
Page 2

If you have any questions regarding the NPDES permit you can contact me at (937) 204-1002 or via email at james.schwieterman@epa.ohio.gov.

Sincerely,

A handwritten signature in black ink, appearing to read "James Schwieterman", with a long horizontal flourish extending to the right.

James Schwieterman
Storm Water Group
Division of Surface Water

JS/kb

Enclosed: Inspection Records

Ohio EPA DSW Storm Water Section, Construction Site Visit Information Form

Inspector initials: JS Visit date: 8/8/13 Permit # 16C04313*AG

Site Name: Jeff Wyler Chevrolet of Springfield

Site Address: 2237 W. First Street Springfield, OH Clark County

People Contacted On Site: Jeff Wyler Dealership Representative

Phone: _____ E-mail: _____

1. Did you see the following on site? Mantain Agency LLC
829 Eastgate South Drive Cincinnati, OH 45245

ITEM	YES	NO	Not Requested	Comments
NOI			✓	Site Parking lot
Coverage Letter			✓	Near completion
SWP3			✓	
Inspection Records			✓	
Contractor & Subs signature document			✓	

2. Acreage Disturbed: 17.00

3. Site Status: Clearing/grubbing Rough Grading Storm sewers in
Streets in Utilities installed Final Grade Final stabilization

4. Are BMPs needed: Yes, Dandy bags (Inlet Protection), Silt Fence

5. Are BMPs effective? All Some None No BMPs

Explain: Dandy Bags on all storm drains (if necessary due to sed ponds)

6. What post construction controls are shown on the SWP3? All storm water drains into sediment ponds

2 sediment ponds (1 north of site + 1 south) completed. Sed pond is effectively holding water with working overflow drain + inlet pipes.

7. Were Photos taken & saved? Yes 8. Was an NOV issued? NO

Additional notes/comments:
 - Look up creek next to site. ~50ft. - small drainage ditch leads to Mad River.
 - Parking lot site with storm drains covered.
 - Once parking is paved, stabilize grass (File NOV)