

40 years and moving forward

Paul R. Kasich, Governor  
Merry Taylor, Lt. Governor  
Scott J. Nally, Director

August 8, 2013

Garry Clarke  
Franklin Park Conservatory  
1777 East Broad Street  
Columbus, OH 43203

**Re: Notice of Termination Inspection at Growing Greenhouse/ Franklin County  
Permit Number: 4GC03470\*AG**

Dear Mr. Clarke:

This letter is written in follow up to a construction storm water inspection by Elizabeth Pleta and Samuel Marotta of the Ohio EPA, we conducted at Growing Greenhouse located at 1810 Franklin Park South on July 25, 2013. The purpose of the inspection was to evaluate compliance with Ohio EPA's General Storm Water Permit Associated with Construction Activities. During the inspection, we noted the following:


It appeared that construction activity has been completed for this site. A Notice of Termination will be required provided the post construction requirements are met. Please address the following:

- Be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days.
- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction mandates can be found at: <http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx>. Please submit to my attention (email preferred at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us)) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria with your submittal.
- A Notice of Termination (NOT) must be submitted once the post construction requirements are verified. The NOT form and filing instructions can be found at: <http://www.epa.state.oh.us/dsw/storm/stormform.aspx>.

Garry Clarke  
Franklin Park Conservatory  
Page 2

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844.

Sincerely,

A handwritten signature in black ink, appearing to read 'Harry Kallipolitis', written over the word 'Sincerely,'.

Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office

HK/nsm Growing Greenhouse 7-25-13