



John D. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nash, Director

August 6, 2013

Doug Swartz
Columbus City Schools, Department of Facilities
889 East 17th Avenue
Columbus, OH 43211

**Re: Notice of Termination Inspection at Alumcrest/Clearbrook 6-12 School/
Franklin County. Permit Number: 4GC03602*AG**

Dear Mr. Swartz:

This letter is written in follow up to a construction storm water inspection by Jerome Hoke and Paul Hafner, of the Ohio EPA, at Alumcrest/Clearbrook 6-12 School located at 2951 South High Street on July 25, 2013. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities.


It appeared during the inspection that construction activity has been completed for this site. A Notice of Termination form is required provided the following items are addressed:

- All areas must be protected from erosion measured by a minimum vegetative density of 70 percent for all disturbed areas.
- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction mandates can be found at: <http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx>. Please submit to my attention (email preferred at harry.kallipolitis@epa.state.oh.us) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria with your submittal.
- If the vegetative requirements above are met please submit your Notice of Termination (NOT) concurrent with your submittal of the post construction verification. The NOT form can be found at: http://www.epa.state.oh.us/portals/35/documents/NOT_app_fis.pdf

Doug Swartz
Columbus City Schools, Department of Facilities
Page 2

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844.

Sincerely,

A handwritten signature in black ink, appearing to read "Harry Kallipolitis". The signature is fluid and cursive, with a large initial "H" and "K".

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

HK/nsm Alumcrest Clearbrook 6-12 School 7-25-13