



John Kasich, Governor
Richard Cordusio, Lieutenant Governor
J. Michael Carter, Director

August 8, 2013

Jerry Warner
City of Delaware
1 South Sandusky Street
Delaware, OH 43015

**Re: Construction Storm Water Inspection at Delaware Fire Station #303 / Delaware County,
Permit Number: 4GCO00087*AG**

Dear Mr. Warner:

This letter is written regarding a storm water inspection conducted by Sam Marotta and Jerome Hoke of the Ohio EPA at Delaware Fire Station #303 at 1320 State Route 37 West on July 24, 2013. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

Sediment and Erosion Control:

- The inlet protections have failed and are not working as intended. Inlet protections are required provided the storm sewer system is not routed to an approved centralized sediment basin or demonstrate an acceptable alternative (See Figure 1).
- Failed silt fence was noted along State Route 37. Corrective measures must be implemented within three days from receipt of this letter (See Figure 2).

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at harry.kallipolitis@epa.state.oh.us.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

HK/nsm Delaware fire Station #303 7-24-13



Figure 1: Storm water drains should be adequately covered.



Figure 2: Failed silt fencing.



Figure 1: Storm water drains should be adequately covered.



Figure 2: Failed silt fencing.