



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

August 14, 2013

Mr. Randy Worley
Messer Construction Co.
4801 Hempstead Station Drive
Dayton, Ohio 45429

RE: Buildings 450 and 451; NPDES Permit 1GC04537*AG; Construction Site Inspection

Dear Mr. Worley:

On Tuesday, August 13, 2013, I inspected Buildings 450 and 451 construction site located on the Wright-Patterson Air Force Base in Ohio, to determine compliance with its NPDES construction site storm water discharge permit. I walked the property with Zachary Olds of WPAFB's environmental management unit.

I did not review sediment control inspection logs, or the site's storm water pollution prevention plan (SWP3). Based on my observations, there were no obvious violations of the project's storm water discharge permit. However, Mr. Olds and I request that the dandy bags that were previously on the inlets of the site, be put back on until adequate vegetation is achieved on the site where there is no danger of sediment-laden water entering the inlets.

As a reminder, compliance with the permit must be upheld until all areas of the site have been permanently stabilized with vegetation or other ground cover. Once final stabilization is achieved, the construction permit must be terminated by completed the one page Notice of Termination (NOT) form found at http://www.epa.ohio.gov/Portals/35/permits/General_NOT.pdf. It must be completed and sent to the following address:

Ohio Environmental Protection Agency
General Permit Program
P.O. Box 1049
Columbus, OH 43216-1049

Buildings 450 and 451 – Construction Site Inspection (NPDES Permit 1GC04537*AG)
August 14, 2013
Page 2

If you have questions regarding this letter, please contact Chris Cotton, who will be taking lead on compliance in this area beginning August 19, 2013. He can be reached at (937) 285-6442, or via email at chris.cotton@epa.ohio.gov.

Sincerely,

A handwritten signature in black ink, appearing to read "Eric Damian", with a long horizontal flourish extending to the right.

Eric Damian
Storm Water Group
Division of Surface Water

ED/tb

ec: Zachary Olds, Water Quality Program Manager, Environmental Quality Section WPAFB