



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

Re: **Notice of Violation**
Auglaize County
Cridersville WWTP
Ohio EPA Permit No. 2PB00048
NPDES Permit No. OH0020222

August 9, 2013

Mr. Jarid Kohrieser
Village Administrator
Village of Cridersville
110 West Main Street
Cridersville, Ohio 45806

Dear Mr. Kohrieser:

We are in receipt of your self-monitoring reports covering the months of April through June 2013 for the referenced facility. Our review indicates violations of the conditions of your National Pollutant Discharge Elimination System (NPDES) permit. The specific instances of non-compliance are enclosed on a separate sheet.

We have received your July 25, 2013, violation response regarding the facility's June 2013 mercury violation and require no further response for that violation. Please inform this office in writing as to the reasons for the enclosed pH violations. Your response will need to include a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions. Please submit your response **within 14 days** of the date of this letter.

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements, including adequate laboratory controls, appropriate quality assurance procedures, and records retention, as specified in your Part III-General Conditions of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code (ORC) Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.


The Ohio EPA strongly encourages pollution prevention as the preferred approach for waste management. The first priority of pollution prevention is to eliminate the generation of wastes and pollutants at the source (source reduction). For those wastes or pollutants that are

Mr. Jarid Kohrieser
August 9, 2013
Page Two

generated, the second priority is to recycle or reuse them in an environmentally sound manner. You can benefit economically, help preserve the environment, and improve your public image by implementing pollution prevention programs. Information about Ohio EPA's Office of Compliance Assistance & Pollution Prevention can be found on Ohio EPA's Website at <http://epa.ohio.gov/ocapp> or by calling (614) 644 – 3469.

If there are any questions, please contact me at (419) 373 – 3022.

Sincerely,



Justin A. Williams
Environmental Specialist II
Division of Surface Water

/jlm

Enclosure

ec: NOV Tracking

Get New Data

Violations for Cridersville WWTW April-June 2013

Permit No	Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
2PB00048*ID	April 2013	001	00400	pH	1D Conc	9.0	9.1	4/3/2013
2PB00048*ID	April 2013	001	00400	pH	1D Conc	9.0	9.1	4/4/2013
2PB00048*ID	June 2013	001	50092	Mercury, Total (Low Le	30D Conc	1.3	1.38	6/1/2013