



John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

Re: **Notice of Violation**  
Allen County  
Indian Village MHP  
Ohio EPA Permit No. 2PY00001  
NPDES Permit No. OH0058319

August 9, 2013

Mr. Dean Skillman  
Park Management Specialists Corporation  
216 West Wayne Street  
Maumee, Ohio 43537-2125

Dear Mr. Skillman:

We are in receipt of your self-monitoring reports covering the months of April through June 2013 for the referenced facility. Our review indicates violations of the conditions of your National Pollutant Discharge Elimination System (NPDES) permit. The specific instances of non-compliance are enclosed on a separate sheet. Further review of your self-monitoring reports for the previous six months, ending in June 2013, indicates that you are in significant non-compliance (SNC) with an effluent limitation contained in your NPDES permit. The specific instance of SNC is enclosed on a separate sheet.

A facility becomes in SNC when it exceeds the effluent limit for four or more months in two consecutive quarters or exceeds the effluent limit significantly in any two months in two consecutive quarters. Achieving compliance with Ohio's environmental laws is a primary focus of Ohio EPA in order to reduce risks to public health and welfare.

It is our understanding that the mobile home park (MHP) is continuing to pursue connection to an Allen County sanitary sewer and will then eliminate its discharge to waters of the State. **Within 14 days** of the date of this letter, please submit a written update as to the status of this project.

The Ohio EPA strongly encourages pollution prevention as the preferred approach for waste management. The first priority of pollution prevention is to eliminate the generation of wastes and pollutants at the source (source reduction). For those wastes or pollutants that are generated, the second priority is to recycle or reuse them in an environmentally sound manner. You can benefit economically, help preserve the environment, and improve your public image by implementing pollution prevention programs. Information about Ohio EPA's Office of Compliance Assistance & Pollution Prevention can be found on Ohio EPA's Website at <http://epa.ohio.gov/ocapp> or by calling (614) 644 – 3469.

If there are any questions or if you wish to meet with our office to discuss this matter; please contact me at (419) 373 – 3022, **within 10 days** of receiving this letter.

Sincerely,

  
Justin A. Williams  
Environmental Specialist II  
Division of Surface Water

/jlm  
Enclosures  
ec: NOV Tracking

Get New Data

Violations for Indian Village MHP - April - June 2013

Permit No	Reporting Period	Reporting		Parameter	Limit Type	Limit	Reported	
		Station	Code				Value	Violation Date
2PY00001*FD	April 2013	001	00530	Total Suspended Solids	1D Conc	18	56.	4/1/2013
2PY00001*FD	April 2013	001	00530	Total Suspended Solids	1D Qty	2.4	6.78272	4/1/2013
2PY00001*FD	April 2013	001	00530	Total Suspended Solids	1D Conc	18	25.	4/8/2013
2PY00001*FD	April 2013	001	00530	Total Suspended Solids	1D Qty	2.4	2.55488	4/8/2013
2PY00001*FD	April 2013	001	00530	Total Suspended Solids	30D Conc	12	25.	4/1/2013
2PY00001*FD	April 2013	001	00530	Total Suspended Solids	30D Qty	1.6	3.02516	4/1/2013

Permit No	Reporting Period	Reporting		Parameter	Sample			Violation Date
		Station	Code		Frequency	Expected	Reported	
2PY00001*FD	April 2013	001	00083	Color, Severity	1/Day	1	0	4/11/2013
2PY00001*FD	April 2013	001	00083	Color, Severity	1/Day	1	0	4/12/2013
2PY00001*FD	April 2013	001	00083	Color, Severity	1/Day	1	0	4/19/2013
2PY00001*FD	April 2013	001	01330	Odor, Severity	1/Day	1	0	4/11/2013
2PY00001*FD	April 2013	001	01330	Odor, Severity	1/Day	1	0	4/12/2013
2PY00001*FD	April 2013	001	01330	Odor, Severity	1/Day	1	0	4/19/2013
2PY00001*FD	April 2013	001	01350	Turbidity, Severity	1/Day	1	0	4/11/2013
2PY00001*FD	April 2013	001	01350	Turbidity, Severity	1/Day	1	0	4/12/2013
2PY00001*FD	April 2013	001	01350	Turbidity, Severity	1/Day	1	0	4/19/2013

Get New  
Data

Get Detail  
for Selected  
Permit

## Facilities in Significant Non-Compliance \*\*

Period: Jan-13 Jun-13

County	Permit #	Facility Name	Major	Station Code	Param Code	Parameter Name	Max % Exceed	# Months Signit Exceed (1)**	# Months Exceed (2)**
Allen	2PY00001	Indian Village MHP		1	00530	Total Suspended Solids	303.1	3	3

### Footnotes

#### for Significant NonCompliance

\*\* Significant non-compliance with effluent limits occurred if one or more pollutants met the following conditions:

1. During 2 or more months, the reported effluent concentration (or computed load) for a parameter exceeded an effluent limit by:
  - a. 40% for Group 1 pollutants **plus Fecal Coliform**
  - b. 20% for Group 2 pollutants **plus pH, Temperature, whole effluent toxicity**-- or --
2. During 4 or more months, the reported concentration (or computed load) exceeded the limit by > 1%.

Note: This method differs from USEPA Significant Non-compliance (SNC) method in the following ways:

- USEPA only evaluates SNC for average limits. In above analyses, maximum and weekly limits were also considered.