



Inhale D. Kasich, Govern  
Elizabeth Taylor, Lt. Governor  
Scott A. Nally, Director

August 12, 2013

David Wespiser  
Hotel Development S  
Services LLV  
125 West Spring Street  
Oxford, OH 45058

**Re: Notice of Termination Inspection at Marriott Courtyard- New Albany,  
Franklin County. Permit Number: 4GC03490\*AG**

Dear Mr. Wespiser:

This letter is written in follow up to a construction storm water inspection by Rachel Bellis and Jerome Hoke of the Ohio EPA, at Marriott Courtyard – New Albany located at 5211 Forest Drive, New Albany, Ohio on July 29, 2013. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, we noted the following:

It appeared during the inspection that construction activity has been completed for this site. A Notice of Termination form is required provided the following items are addressed:

- All areas must be protected from erosion measured by a minimum vegetative density of 70 percent for all disturbed areas.
- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction mandates can be found at: <http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx>. Please submit to my attention (email preferred at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us)) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria with your submittal.
- If the vegetative requirements above are met please submit your Notice of Termination (NOT) concurrent with your submittal of the post construction verification. The NOT form can be found at: [http://www.epa.state.oh.us/portals/35/documents/NOT\\_app\\_fis.pdf](http://www.epa.state.oh.us/portals/35/documents/NOT_app_fis.pdf)

David Wespiser  
Hotel Development S  
Services LLV  
Page -2-

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844.

Sincerely,

A handwritten signature in dark ink, appearing to read "Harry Kallipolitis", with a horizontal line extending to the right.

Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office

HK/nsm    Marriott Courtyard New Albany 7-29-13