



John F. Kasich, Governor or  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

August 19, 2013

David Mills  
Woolpert Inc  
2780 Airport Drive, Suite 100  
Columbus, Ohio 43212

**Re: Notice of Termination Inspection at Firestone Auto Care Center / Franklin County. Permit Number: 4GC03525\*AG**

Dear Mr. Mills:

This letter is written in follow up to a construction storm water inspection by Sam Marotta and Paul Hafner, of the Ohio EPA at Firestone Auto Care Center located at 5385 New Albany Road on July 30, 2013. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, we noted the following:

It appeared during the inspection that construction activity has been completed for this site. A Notice of Termination form is required provided the following items are addressed:

- All areas must be protected from erosion measured by a minimum vegetative density of 70 percent for all disturbed areas.
- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction mandates can be found at: <http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx>. Please submit to my attention (email preferred at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us)) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria with your submittal.
- If the vegetative requirements above are met please submit your Notice of Termination (NOT) concurrent with your submittal of the post construction verification. The NOT form can be found at: [http://www.epa.state.oh.us/portals/35/documents/NOT\\_app\\_fis.pdf](http://www.epa.state.oh.us/portals/35/documents/NOT_app_fis.pdf)

David Mills2  
Woolpert Inc  
Page

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844.

Sincerely,



Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office

HK/nsm Firestone Auto Care Center 7-30-13