



John E. Kasich, Governor
Betsy Taylor, Lt. Governor
Scott L. Mallory, Director

August 19, 2013

Jeff Feltz
City of Gahanna
200 South Hamilton Road
Gahanna, OH 43230

Re: Notice of Termination Inspection at McKenna Creek Stormwater Management Facility / Franklin County. Permit Number: 4GC03618*AG

Dear Mr. Feltz:

This letter is written in follow-up to a construction storm water inspection by Rachel Bellis and Jerome Hoke of the Ohio EPA, at McKenna Creek Stormwater Management Facility located at North Hamilton Road on July 29, 2013. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, we noted the following:

It appeared during the inspection that construction activity has been completed for this site. A Notice of Termination form is required provided the following items are addressed:

- All areas must be protected from erosion measured by a minimum vegetative density of 70 percent for all disturbed areas.
- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction mandates can be found at: <http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx>. Please submit to my attention (email preferred at harry.kallipolitis@epa.state.oh.us) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria with your submittal.
- If the vegetative requirements above are met please submit your Notice of Termination (NOT) concurrent with your submittal of the post construction verification. The NOT form can be found at: http://www.epa.state.oh.us/portals/35/documents/NOT_app_fis.pdf

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844.

Sincerely,


Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

HK/nsm McKenna Creek Stormwater Management Facility 7-29-45