



40 years and counting forward

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

August 19, 2013

Newman Babieh
ODOT- District 5
9600 Jacksontown Road Southeast
Jacksontown, OH 43030

RE: Construction Storm Water Inspection at LIC- 70-13.00 (PID 85540) PID- 85540/ Licking County, Permit Number: 4GC03982*AG

Dear Mr. Babieh:

This letter is written regarding a storm water inspection I conducted at LIC- 70-13.00 (PID 85540) PID- 85540 located at Interstate 70 and Canal Road (TR 171) on July 29, 2013. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit associated with Construction Activities. During the inspection I noted the following issues associated with construction activities at this site:

Sediment and Erosion Control

- Construction activities continue within the median of Interstate 70. The inlet protections serve as the primary sediment control for all the disturbed areas within the median. Continued maintenance is expected to ensure full compliance of the General Permit. All inlets must be designed to impound water to ensure the intended function.
- It appears that the intersection of Canal Road and Interstate 270 have exceeded the 21 day criteria. The General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days.

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844 or email at harry.kallipolitis@epa.state.oh.us. In addition, please provide a written response (**email preferred**) to the action items addressed above within ten days from receipt of this letter. A follow up inspection will be conducted to ensure the minimum conditions of the General Permit have been met.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

HK/nsm LIC 70-13 00(PID 85540) 7-31-2013 (2)