



John E. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

August 19, 2013

John Johnston  
John D Johnston Architects  
3955 Montgomery Road  
Cincinnati, OH 45212

**Re: Construction Storm Water Inspection at United Dairy Farmers / Franklin County.  
Permit Number: 4GC03984 \*AG**

Dear Mr. Johnston:

This letter is written regarding a storm water inspection conducted by Jerome Hoke and Rachel Bellis, of the Ohio EPA, at United Dairy Farmers located on the southwest corner of U.S. Route 62 and Ridenour Road on July 29, 2013. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

**Sediment and Erosion Control:**

- The sediment controls that encompass the site appear to be in order. Please ensure continual maintenance on this perimeter control, particularly on the southern portion of this site.
- Be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days.

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844 or email at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us). In addition, please provide a written response (**email preferred**) to the action items addressed above within ten days from receipt of this letter. A follow up inspection will be conducted to ensure the minimum conditions of the General Permit have been met.

Sincerely,

Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office

HK/nsm United Dairy Farmers 7-29-2013