



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Pully, Director

August 19, 2013

Tucker Bohm
The Daimler Group
1533 Lakeshore Drive
Columbus, OH 43204

**Re: Construction Storm Water Inspection at Sarcom/ Franklin County, Permit
Number: 4GC04054*AG**

Dear Mr. Bohm:

This letter is written regarding a storm water inspection I conducted at Sarcom located at the northeast corner of New Albany Road East and Souder Road in New Albany, Ohio on July 30, 2013. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit associated with Construction Activities. During the inspection I noted the following issues associated with construction activities at this site:

Sediment and Erosion Control:

- The modified outlet structure to address appropriate sediment control must be installed within 10 days of receiving this letter.
- Dewatering activities must be conducted in such a manner not to result in turbid discharge to waters of the state or to associated conveyance such as a storm sewer or road side ditch.
- Please provide containment measures for all concrete washout activities conducted on this site.
- Be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days.

Tucker Bohm
The Daimler Group
Page 2

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844 or email at harry.kallipolitis@epa.state.oh.us. In addition, please provide a written response (***email preferred***) to the action items addressed above within ten days from receipt of this letter. A follow-up inspection will be conducted to ensure the minimum conditions of the General Permit have been met.

Sincerely,



Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

HK/nsm Sarcom 7-30-13