



John E. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott A. Nisley, Director

August 19, 2013

Todd Sloan  
The Daimler Group  
1533 Lake Shore Drive  
Columbus, OH 43204

**Re: Construction Storm Water Inspection at Exhibit Pro/ Licking County  
Permit Number: 4GC04055\*AG**

Dear Mr. Sloan:


This letter is written regarding a storm water inspection conducted by Rachel Bellis and Jerome Hoke of the Ohio EPA at Exhibit Pro located at the north side of Smiths Mill Road, northeast of Beech Road on July 29, 2013. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

**Sediment and Erosion Control:**

- The sediment and erosion controls at this site are currently functioning properly. Please continue to monitor and ensure continued compliance with the General Storm Water Permit Associated with Construction Activities.
- Please ensure positive flow from all affected areas to the basin intended for sediment control.
- Be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days.

If you have any question regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844 or email at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us). A follow-up inspection will be conducted to ensure the conditions of the General Permit are met.

Sincerely,



Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office

HK/nsm Exhibit Pro 7-29-2013