



10 years and moving forward

John Kasich, Governor  
Marilyn Taylor, Lt. Governor  
Scott J. Nally, Director

August 19, 2013

Mark Waller  
South- Western City Schools  
3805 Marlene Drive  
Grove City, OH 43123

**Re: Construction Storm Water Inspection at Franklin Heights High School and West Franklin Elementary School/ Franklin County, Permit Number: 4GC04182\*AG**

Dear Mr. Waller:

This letter is written regarding a storm water inspection conducted by Paul Hafner and Jerome Hoke of the Ohio EPA at Franklin Heights High School and West Franklin Elementary School located at South West Corner of Briggs Road and Demorest Avenue on July 23, 2013. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

**Sediment and Erosion Control:**

- It appeared dewatering activities were taking place along the northern portion of the site. Please ensure all dewatering activities do not result in turbid discharge into waters of the state. (**Figure 1**).
- A sediment impoundment was noted on the northwest corner of the site. Please ensure the sediment impoundment is equipped with approved riser or skimmer within seven (7) days after receipt of this letter.
- Be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days

Mark Waller  
South- Western City Schools  
Page 2

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844 or email at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us). In addition, please provide a written response (***email preferred***) to the action items addressed above within ten days from receipt of this letter. A follow up inspection will be conducted to ensure the minimum conditions of the General Permit have been met.

Sincerely,



Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office