



40 years and moving forward

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

August 23, 2013

Nicholas Domenick  
City of Columbus- Department of Public Utilities  
910 Dublin Road  
Columbus, OH 43215

Re: Construction Storm Water Inspection at 3<sup>rd</sup> Avenue and Edgehill Road / Franklin County. Permit Number: 4GC03803 \*AG

Dear Mr. Domenick:

This letter is written regarding a storm water inspection I conducted at 3<sup>rd</sup> Avenue and Edgehill Road, located from Norton Avenue to Olentangy River Road, and Edgehill Road on August 1, 2013. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

**Sediment and Erosion Control:**

- The sediment and erosion controls at this site are currently functioning properly. Please continue to monitor and ensure continued compliance with the General Storm Water Permit Associated with Construction Activities.
- Be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us).

Sincerely,

Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office

HK/nsm 3<sup>rd</sup> Avenue and Edgehill road 8-1-13