



August 23, 2013

Gary Nuss
Nationwide Realty Investors
375 North Front Street, Suite 200
Columbus, OH 43216

Re: Construction Storm Water Inspection at Proposed Ditch #1 and #2/ Franklin County. Permit Number: 4GC04167*AG

Dear Mr. Nuss:

This letter is written regarding a storm water inspection I conducted at Proposed Ditch #1 and #2 located north of Goodale Boulevard and east of Yard Street on August 1, 2013. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit associated with Construction Activities.

Sediment and Erosion Control:

- Be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days. I advise that efforts be concentrated on seeding.

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844 or email at harry.kallipolitis@epa.state.oh.us.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

HK/nsm Proposed Ditch #1 and #2 8-1-13