



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

August 28, 2013

Re: Scioto County
Eden Park Sanitary Sewer
Storm Water Construction Activity
Permit #0GC01881*AG

Mr. Terry Brown
J&H Erectors, Inc.
1406 Tenth Street
P.O. Box 60
Portsmouth, Ohio 45662

H. Patrick Karnes
Strand Associates, Inc.
4433 Professional Parkway
Groveport, Ohio 43125

Mr. Joseph Delong
602 Seventh Street
Room 104
Portsmouth, Ohio 45662

Dear Mr. Brown:

On August 7, 2013, I visited the site located in the vicinity of State Route 139 and Rosemount Road that has a construction storm water permit with the Ohio EPA. The purpose of my inspection was to determine the compliance of this site with the National Pollutant Discharge Elimination System (NPDES) permit for discharges of storm water associated with construction activity. The inspection was conducted under the provisions of Ohio's water pollution control statues, Ohio Revised Code (ORC) Chapter 6111.

No violations of the terms and conditions of the permit were discovered. Please continue to implement permit requirements as construction continues.

I have the following comments regarding my visit:

- **Please continue working with local home owners to ensure adequate storm water controls remain in place through the entire project.**
- **Once the ordered mulch sock arrives on site, please use the product to increase sediment control around the project area.**
- **Please repair the silt fence surrounding the active storage pile on Hinkley Hollow Road.**

As a reminder, if your project disturbs more than five acres you are required to implement post construction water quality volume storage requirements with permanent storm water management structures as required by the permit.

If there are any questions, please contact Aaron Wolfe at (740) 380-5277 or myself at (740) 380-5447.

Sincerely,

A handwritten signature in blue ink that reads "Jennifer M. Wette" with "for" written below it.

Jared Kemper
Storm Water Section
Division of Surface Water

JCK/dh