



John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

August 28, 2013

**Re:** Belmont County  
Ye Olde Barn RV Park  
Storm Water Construction Activity  
Permit #OGC01893\*AG

Mr. Dean Miller  
67230 Stein Road  
Belmont, Ohio 43718

Dear Mr. Miller:

On August 5, 2013, I visited the site located on National Road that has a construction storm water permit with the Ohio EPA. The purpose of my inspection was to determine the compliance of this site with the National Pollutant Discharge Elimination System (NPDES) permit for discharges of storm water associated with construction activity. The inspection was conducted under the provisions of Ohio's water pollution control statues, Ohio Revised Code (ORC) Chapter 6111.

**No violations of the terms and conditions of the permit were discovered. Please continue to implement permit requirements as construction continues.**

As a reminder, the drainage swale that was cut down the hill should be permanently stabilized within 7 days of the most recent disturbance as required by the permit. Permanent stabilization is defined as the establishment of permanent vegetative cover, decorative landscape mulching, matting, sod, rip rap and landscaping techniques to provide permanent erosion control. Also, regarding technical assistance for silt fence installation, the silt fence should be trenched into the ground at least 6 inches. Sediment deposits should be routinely removed when they reach approximately one-half the height of the silt fence.

If there are any questions, please contact Aaron Wolfe at (740) 380-5277 or myself at (740) 380-5447.

Sincerely,

A handwritten signature in blue ink, which appears to read "Clinton Kuenzli".

Clinton Kuenzli  
Storm Water Section  
Division of Surface Water

CDK/dh