



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

Re: Lucas County
Highland Meadows &
Griffith Park Subdivisions Road
Construction Storm Water
Facility ID No. 2GC02703

August 21, 2013

Mr. Jeffrey Ballmer
City of Sylvania
6730 Monroe Street
Sylvania, Ohio 43560

Dear Mr. Ballmer:

On May 30, 2013, Zachary Titkemeier and Tom Wilkins inspected the Highland Meadows & Griffith Park Subdivisions Road at Altara Drive, Gillingham Drive, Gillingham Court, Graystone Drive and Gregory Drive, Sylvania (photos taken). The purpose of their visit was to evaluate compliance of the site with the National Pollutant Discharge Elimination System (NPDES) permit for storm water discharges associated with construction activity. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111.

It appears that construction activities at the Highland Meadows & Griffith Park Subdivisions Road are complete. Newly paved roads were present. A Notice of Termination (NOT) must be filed to relieve you of the obligation to comply with this general permit. An NOT may be filed if one or more of the following conditions have been met:


- Final stabilization has been established on all areas of the site for which the permittee is responsible. Final stabilization means that all soil disturbing activities at the site are complete and a uniform perennial vegetative cover of at least 70% density has been established over the entire site. All temporary erosion and sediment control measures have been removed, properly disposed of, and all trapped sediment has been permanently stabilized; or
- Another operator(s) has assumed control over all areas of the site that have not been fully stabilized.

Mr. Jeffrey Ballmer
August 21, 2013
Page Two

It appears that you have met these criteria, so you may file an NOT. The NOT form and instructions can be found on our website: <http://www.epa.ohio.gov/dsw/storm/stormform.aspx>. NOTs must be mailed to Ohio EPA's Central Office within 45 days of when the above criteria are met.

If there are any questions, please contact me at 419-373-3009.

Sincerely,



Lynette Hablitzel, P.E.
Division of Surface Water
Storm Water Program

/jlm

ec: Tracking