



John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

Re: Lucas County  
West Side Montessori Center  
Construction Storm Water  
Facility ID No. 2GC02964\*AG

August 21, 2013

Ms. Lynn Fisher  
West Side Montessori Center  
7115 Bancroft Street  
Toledo, Ohio 43615

Mr. Mike Provaznik  
Provo Construction Company, LLC  
3359 Silica Road Unit A  
Sylvania, Ohio 43560

Dear Ms. Fisher and Mr. Provaznik:

On June 3, 2013, Zach Titkemeier and Tom Wilkins inspected the Westside Montessori Center School, Toledo (photo taken). The purpose of the visit was to evaluate compliance of the site with the National Pollutant Discharge Elimination System (NPDES) permit for storm water discharges associated with construction activity. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111.

At the time of inspection, construction at the site seemed to be nearly complete. The new school building had been finished and operational for about a year, according to one of the staff members with whom we spoke in the lobby area on the day of inspection. A bioretention area was present inside the parking area north of the new building and a preexisting retention pond was present along the southern property line. A full cover of grass had been established on some portions of the site, but bare sandy soil was exposed on other portions. Several patches of bare soil were noted throughout the property, most notably along Bancroft Street and along the east side of the property. **These must be stabilized.** Please see Part III.G.2.b.i. of the permit.

Within 10 days of the date on this letter, please submit to this office written notification as to the actions taken or proposed to prevent future violations. Your response should include the dates, either actual or proposed, for the completion of the actions.

If there are any questions, please contact me at 419-373-3009.

Sincerely,

Lynette Hablitzel, P.E.  
Division of Surface Water  
Storm Water Program

/jlm  
ec: Tracking