



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

Re: Huron County
North Coast Inland Trail
Construction Storm Water
Facility ID No. 2GC03050

August 21, 2013

Mr. Dan Martin
Lorain County Metro Parks
12882 Diagonal Road
Lagrange, Ohio 44050

Dear Mr. Martin:

On June 20, 2013, Zachary Titkemeier and Tom Wilkins inspected the North Coast Inland Trail south of railroad tracks on South Main Street, Monroeville (photos taken). The purpose of the visit was to evaluate compliance of the site with the National Pollutant Discharge Elimination System (NPDES) permit for storm water discharges associated with construction activity. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111.

It appears that construction activities at the North Coast inland trail are complete. A gravel path and detention pond was present. A Notice of Termination (NOT) must be filed to relieve you of the obligation to comply with this general permit. An NOT may be filed if one or more of the following conditions have been met:


- Final stabilization has been established on all areas of the site for which the permittee is responsible. Final stabilization means that all soil disturbing activities at the site are complete and a uniform perennial vegetative cover of at least 70% density has been established over the entire site. All temporary erosion and sediment control measures have been removed, properly disposed of, and all trapped sediment has been permanently stabilized; or
- Another operator(s) has assumed control over all areas of the site that have not been fully stabilized.

Mr. Dan Martin
August 21, 2013
Page Two

It does not appear that you have met these criteria yet, as there were areas where the grass cover had not yet reached a 70% density. Once you have met these criteria, you may file the NOT form. The NOT form and instructions can be found on our website: <http://www.epa.ohio.gov/dsw/storm/stormform.aspx>. NOTs must be mailed to Ohio EPA's Central Office within 45 days of when the above criteria are met.

If there are any questions, please contact me at 419-373-3009.

Sincerely,



Lynette Hablitzel, P.E.
Division of Surface Water
Storm Water Program

/jlm

cc: Mike Goodwin Village Administrator
Tracking