



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

Re: **Notice of Violation**
Wood County
Grand Rapids School
Construction Storm Water
Permit No. 2GC03450AG

August 29, 2013

Mr. Adam Koch
Garmann-Miller
38 South Lincoln Drive
Minster, Ohio 45865

Dear Mr. Koch:

On August 12, 2013, I performed an inspection of the Grand Rapids Elementary School project located at 17595 Bridge Street in the Village of Grand Rapids, Wood County. The purpose of this visit was to evaluate compliance of the site with the National Pollutant Discharge Elimination System (NPDES) permit for storm water discharges associated with construction activity (Construction General Permit or CGP). The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111.

At the time of the inspection, the demolition area was fenced and the school had been razed. There were piles of brick, concrete and other rubble on site. A storm water pollution prevention plan and inspection reports were not viewed during the inspection.

There was no inlet protection on catch basins in the area. *This is a violation of Part III.G.2.d.iv of the CGP.*

Within 15 days of the date on this letter, please submit to this office **written notification** of the actions taken or proposed to prevent any future violations. Your response should include the dates, either actual or proposed, for the completion of the actions.

If you have any questions, you may contact me at (419) 373-3016 or by e-mail at patricia.tebbe@epa.ohio.gov.

Sincerely,

Patricia A. Tebbe, P.E.
Division of Surface Water

/jlm

pc: Wood County Engineer
Wood County SWCD
Abdoo Brothers Demolition Ltd.

ec: Tracking