



John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

Re: Huron County  
Fisher-Titus Medical Center  
Construction Storm Water  
Facility ID No. 2GC02868

August 21, 2013

Ms. Lorna Strayer  
Fisher-Titus Medical Center  
272 Benedict Avenue  
Norwalk, Ohio 44857

Dear Ms. Strayer:

On June 17, 2013, Zachary Titkemeier and Tom Wilkins inspected the Fisher-Titus Medical Center at 272 Benedict Avenue, Norwalk (photos taken). The purpose of their visit was to evaluate compliance of the site with the National Pollutant Discharge Elimination System (NPDES) permit for storm water discharges associated with construction activity. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111.

It appears that construction activities at the Fisher-Titus Medical Center are complete. A renovated wing of the main building was present. It appeared that a retention pond had been installed west of the building to meet the post construction storm water management requirements of the permit. A Notice of Termination (NOT) must be filed to relieve you of the obligation to comply with this general permit. An NOT may be filed if one or more of the following conditions have been met:


- Final stabilization has been established on all areas of the site for which the permittee is responsible. Final stabilization means that all soil disturbing activities at the site are complete and a uniform perennial vegetative cover of at least 70% density has been established over the entire site. All temporary erosion and sediment control measures have been removed, properly disposed of, and all trapped sediment has been permanently stabilized; or
- Another operator(s) has assumed control over all areas of the site that have not been fully stabilized.

Ms. Lorna Strayer  
August 21, 2013  
Page Two

It appears that you may soon meet these criteria. Once a 70% density of vegetative cover has been established, you may file the NOT form. The NOT form and instructions can be found on our website: <http://www.epa.ohio.gov/dsw/storm/stormform.aspx>. NOTs must be mailed to Ohio EPA's Central Office within 45 days of when the above criteria are met.

If there are any questions, please contact me at 419-373-3009.

Sincerely,



Lynette Hablitzel, P.E.  
Division of Surface Water  
Storm Water Program

/jlm

cc: Josh Snyder, Norwalk City Engineer  
Tracking