



John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

Re: Lucas County  
Ottawa Hills High School  
Construction Storm Water  
Facility ID No. 2GC02377

August 21, 2013

Mr. Don Traska  
Kiefer Specialty Flooring  
2910 Falling Waters Boulevard  
Lindenhurst, Illinois 60646

Dear Mr. Traska:

On June 3, 2013, Zachary Titkemeier and Tom Wilkins inspected Ottawa Hills High School at 2532 Evergreen Road, Toledo (photos taken). The purpose of their visit was to evaluate compliance of the site with the National Pollutant Discharge Elimination System (NPDES) permit for storm water discharges associated with construction activity. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111.

It appears that construction activities at Ottawa Hills High School are complete. A new football field and goal posts were present. A Notice of Termination (NOT) must be filed to relieve you of the obligation to comply with this general permit. An NOT may be filed if one or more of the following conditions have been met:


- Final stabilization has been established on all areas of the site for which the permittee is responsible. Final stabilization means that all soil disturbing activities at the site are complete and a uniform perennial vegetative cover of at least 70% density has been established over the entire site. All temporary erosion and sediment control measures have been removed, properly disposed of, and all trapped sediment has been permanently stabilized; or
- Another operator(s) has assumed control over all areas of the site that have not been fully stabilized.

Mr. Don Traska  
August 21, 2013  
Page Two

It appears that your site may meet these criteria. Once a 70% density of vegetative cover has been established, you may file the NOT form. The NOT form and instructions can be found on our website: <http://www.epa.ohio.gov/dsw/storm/stormform.aspx>. NOTs must be mailed to Ohio EPA's Central Office within 45 days of when the above criteria are met.

If there are any questions, please contact me at 419-373-3009.

Sincerely,



Lynette Hablitzel, P.E.  
Division of Surface Water  
Storm Water Program

/jlm

ec: Tracking