



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

Re: Hancock County
University of Findlay
Davis Street Building Addition
Construction Storm Water
Facility ID No. 2GC02990*AG

August 21, 2013

Mr. Myreon Cobb
University of Findlay
1000 North Main Street
Findlay, Ohio 45840

Dear Mr. Cobb:

On June 7, 2013, Zachary Titkemeier and Tom Wilkins inspected the University of Findlay Davis Street Building Addition at 300 Davis Street, Findlay. The purpose of the visit was to evaluate compliance of the site with the National Pollutant Discharge Elimination System (NPDES) permit for storm water discharges associated with construction activity. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111.

It appears that construction activities at the Davis Street Building Addition are complete. A finished building and paved parking areas were present. A Notice of Termination (NOT) must be filed to relieve you of the obligation to comply with this general permit. An NOT may be filed if one or more of the following conditions have been met:


- Final stabilization has been established on all areas of the site for which the permittee is responsible. Final stabilization means that all soil disturbing activities at the site are complete and a uniform perennial vegetative cover of at least 70% density has been established over the entire site. All temporary erosion and sediment control measures have been removed, properly disposed of, and all trapped sediment has been permanently stabilized; or
- Another operator(s) has assumed control over all areas of the site that have not been fully stabilized.

Mr. Myreon Cobb
August 21, 2013
Page Two

While construction activities were complete, it was not apparent what post construction storm water management controls had been installed. The permit requires that post-construction Best Management Practices (BMPs) are installed during construction to control pollutants in the storm water discharges that will occur after construction has concluded. Such practices may include, but are not limited to: storm water extended detention structures; retention structures; water quality swales; and bioretention areas. Please send a written response describing what post construction storm water management practices are being/will be implemented at the site within 10 days of the date on this letter. Your reply should include the type(s) of practices, the basis for its design, and installation dates. When all permit conditions have been met, you may file the NOT form. The NOT form and instructions can be found on our website: <http://www.epa.ohio.gov/dsw/storm/stormform.aspx>. NOTs must be mailed to Ohio EPA's Central Office within 45 days of when the above criteria are met.

If there are any questions, please contact me at 419-373-3009.

Sincerely,



Lynette Hablitzel, P.E.
Division of Surface Water
Storm Water Program

/jlm

ec: Tracking