



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

Re: Seneca County
Construction Storm Water
Greenfield St Market St Perry St Intersection
Facility ID No. 2GC03047
Rock Creek Interceptor Project
Facility ID No. 2GC02905

August 21, 2013

Mr. Curtis Eagle
City of Tiffin
51 East Market Street
Tiffin, Ohio 44883

Dear Mr. Eagle:

On June 25, 2013, Zachary Titkemeier and Tom Wilkins inspected the Greenfield Street-Market Street- Perry Street Intersection at 310 East Market Street, Tiffin (photos taken). They also inspected the Rock Creek Interceptor Project along Rock Creek from Circular Street to Summit Street, Tiffin. The purpose of their visits were to evaluate compliance of the sites with the National Pollutant Discharge Elimination System (NPDES) permit for storm water discharges associated with construction activity. The inspections were conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111.

It appears that construction activities at the Greenfield Street-Market Street-Perry Street Intersection are complete. A newly paved intersection and new curbs were present. Construction activities at the Rock Creek Interceptor Project also appear to be complete. Multiple new sanitary sewer manholes were present. A Notice of Termination (NOT) must be filed for each site to relieve you of the obligation to comply with this general permit. An NOT may be filed if one or more of the following conditions have been met:


- Final stabilization has been established on all areas of the site for which the permittee is responsible. Final stabilization means that all soil disturbing activities at the site are complete and a uniform perennial vegetative cover of at least 70% density has been established over the entire site. All temporary erosion and sediment control measures have been removed, properly disposed of, and all trapped sediment has been permanently stabilized; or
- Another operator(s) has assumed control over all areas of the site that have not been fully stabilized.

Mr. Curtis Eagle
August 21, 2013
Page Two

While the Greenfield Street-Market Street-Perry Street Intersection project appears to have met these criteria, there appears to be several areas where a 70% density had not yet been reached on the Rock Creek Interceptor project. Once you have met these criteria, you may file the NOT form. The NOT form and instructions can be found on our website: <http://www.epa.ohio.gov/dsw/storm/stormform.aspx>. NOTs must be mailed to Ohio EPA's Central Office within 45 days of when the above criteria are met.

If there are any questions, please contact me at 419-373-3009.

Sincerely,



Lynette Hablitzel, P.E.
Division of Surface Water
Storm Water Program

/jlm

ec: Tracking