



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

Re: Lucas County
Construction Storm Water
Crimson Hollow Plats 7 & 8
Facility ID No. 2GC03411*AG

August 21, 2013

Mr. Don Ulrich
LCH Holding Company, LLC
8057 English Garden Court
Maumee, Ohio 43537

Dear Mr. Ulrich:

On May 22, 2013, Zachary Titkemeier, Tom Wilkins, and I inspected Crimson Hollow Plats 7 & 8 located south of Stitt Road and west of Waterville Monclova Road, Waterville. Follow-up inspections were conducted by Zach and Tom on June 24, and August 2, 2013. The purpose of the visits was to evaluate compliance of the site with the National Pollutant Discharge Elimination System (NPDES) permit for storm water discharges associated with construction activity. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111.

On each occasion, no earthwork was occurring and no construction equipment was present. When construction does commence, please remember the permit requirements for storm water management during construction and post construction, such as weekly self-inspections and the requirement to apply cover within seven days on bare soil in **any areas that will sit idle for more than 14 days**. Your sediment controls must be installed within seven days of grubbing and before any grading.

Please send a written reply within 10 days of the date of this letter describing how the post construction storm water management requirements will be met. Your reply should include the type(s) of practices you are implementing and the basis for their design. If there are any questions, please contact me at 419-373-3009.

Sincerely,

A handwritten signature in black ink, appearing to read "Lynette Hablitzel".

Lynette Hablitzel, P.E.
Division of Surface Water
Storm Water Program

/jlm
ec: Tracking