



August 27, 2013

John Donley
Donley, Inc.
7600 Farmsbury Dr.
Reynoldsburg, OH 43068

Re: Meadowmoore, Sec. 3, Ph. 1-4, Fairfield County

Dear Mr. Donley:

This letter is written regarding the storm water inspection that I conducted on July 10, 2013, at Meadowmoore, Sec. 3, Ph. 1-4, located along Milnor Road. I understand that these construction activities are covered under the General Storm Water Permit Associated with Construction Activities. Based on my site inspection and the General Storm Water Permit, the following items must be addressed:

Sediment and Erosion Controls:

Overall, the site appeared in compliance with the General Storm Water Permit. There were about five homes under construction. There was one home that needed to have the erosion controls maintained.

Please be aware that the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days. There were several sites that appeared to be near final grade.

If you have any questions regarding this letter or my inspection, please do not hesitate to call me at our Central District Office at (614) 728-3851.

Sincerely,

Gregory L. Sanders
Environmental Specialist
Division of Surface Water
Central District Office

ec: Greg Sanders, DSW/CDO