



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Holtz, Director

August 28, 2013.

Chris Lagana
Mount Carmel Health System
6150 East Broad Street
Third Floor
Columbus, OH 43213

**RE: Mount Carmel Health Ambulatory Facility, Franklin County
Permit Number: 4GC03950 *AG**

Dear Mr. Lagana:

This letter is written in response to my storm water inspection on August 26, 2013, of the construction activities associated with the Mount Carmel Health Ambulatory Facility, located near the intersection of Hoover and Holton Roads, in Grove City, Ohio. Based on my site observations of the site and the conditions of the Storm Water Permit, the following items were noted.

Sediment and Erosion Controls:

1. There was active construction at the site. Erosion controls, such as silt fence, was installed and maintained around the project area.
2. Stone was installed at the entrance along Hoover Road to prevent mud being tracked off-site. A tire washing station had also been installed to further help prevent mud from being tracked on to Hoover Road. Please insure that the wash water from the tire washing station is captured and does not run off-site.
3. A copy of the storm water pollution prevention plan was located at the construction trailer for my review as requested. The weekly inspection log was also available to me at the construction trailer.
4. Please place a sign at the concrete wash-out pit to notify the concrete haulers of its location.

Chris Lagana
Mount Carmel Health System
Page 2

If you have any questions regarding this letter or my inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844.

Sincerely



Gregory L. Sanders
Storm Water Unit
Division of Surface Water
Central District Office

c: Aaron Heironimus, Quandell
Craig King, Quandell