



John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

August 29, 2013

**Re:** Ross County  
Hospital Road Sewer Expansion  
Storm Water Construction Activity  
Permit #0GC01323\*AG

Mr. Fred Woodruff  
City of Chillicothe Utilities Dept.  
35 S. Paint Street  
Chillicothe, Ohio 45601

Dear Mr. Woodruff:

On August 14, 2013, I visited the site located at the intersection of Hospital and Delano Road. The purpose of my site visit and inspection was to determine the compliance of this site with the National Pollutant Discharge Elimination System (NPDES) permit for discharges of storm water associated with construction activity. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111.

At the time of my inspection, the site was inactive and it appeared that construction activities had been completed. In accordance with the NPDES permit, a Notice of Termination (NOT) must be submitted to the Ohio Environmental Protection Agency (Ohio EPA) to release you from the terms and conditions of this permit.

A NOT may be submitted to Ohio EPA if the following requirements have been fulfilled:

1. A perennial vegetative cover (or equivalent means of stabilization) has been established over 100% of the surface area disturbed during construction. The vegetative growth must be at a growth density of 70%.
2. All temporary sediment and erosion controls have been removed and properly disposed.
3. All sediment has been permanently stabilized to prevent further erosion.
4. Construction activity at the site has ceased.

It appears that your site meets the above criteria. If you agree, please submit a NOT within 45 days of the completion of construction activities. Failure to submit a NOT is a violation of the permit requirements and may affect your ability to obtain a NPDES

permit in the future. If your project has not yet begun or future phases of the project are planned please do not submit your NOT.

Please send the completed NOT to the following address:

Ohio Environmental Protection Agency  
Division of Surface Water  
Storm Water Section  
P.O. Box 1049  
Columbus, Ohio 43216-1049

If you have any questions, please contact me at (740) 380-5277.

Sincerely,



Aaron Wolfe  
Storm Water Section  
Division of Surface Water

AW/dh

Enclosure: Notice of Termination