



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

August 30, 2012

Re: Adams County
Peebles Test Operation
Storm Water Construction Activity
0GC01805*AG
0GC01806*AG

Mr. Carl Trotter
General Electric Aircraft Engines
1200 Jaybird Road
Peebles, Ohio 45660

Dear Mr. Trotter:

On July 16, 2012, I visited the sites located at 1200 Jaybird Road in Peebles, Ohio that have construction storm water permits with the Ohio EPA. The purpose of my inspection was to determine the compliance of this site with the National Pollutant Discharge Elimination System (NPDES) permit for discharges of storm water associated with construction activity. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111. As a result of the inspection, I have the following comments:

Although no violation was noted please ensure that all silt fence is maintained properly and that the compressor station sump area is cleaned out and maintained to avoid the possibility of turbid water being discharged from the site.

As a reminder, if your project disturbs more than five acres you are required to implement post construction water quality volume storage requirements with permanent storm water management structures as required by the permit.

If there are any questions, please contact me at (740) 380-5277.

Sincerely,

Jennifer M. Witte
for

Aaron Wolfe
Storm Water Section
Division of Surface Water

AW/dh