



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

August 29, 2013

Re: Washington County
North Hills Terrace Subdivision
Storm Water Construction Activity
Notice of Violation
Permit OGC01943*AG

Mr. Bruce Brunton
Brunton Development LLC
1100 Greene Street
Marietta, Ohio 45750

Dear Mr. Brunton:

On August 22, 2013, I visited your site on Colegate Drive. The purpose of the inspection was to determine the compliance of this site with the National Pollutant Discharge Elimination System (NPDES) permit for discharges of stormwater associated with construction activity. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111. I have the following comments:

Permit Coverage:

Part III.G.2.d.iv. of the permit states that sediment control practices must minimize the amount of sediment entering an active storm drain system, unless the system drains to a sediment settling pond.

At the time of inspection, sediment had accumulated on a portion of concrete driveway next to an unprotected storm drain. Please install inlet protection and sweep or scrape the sediment from the driveway area. Also please sweep or scrape the accumulated sediment at the entrance at the bottom of the hill where water has ponded. Do not rinse sediment into a storm drain system.

Sediment and erosion controls for your site must meet the guidelines and design criteria set forth in the above mentioned *Rainwater and Land Development* manual. A copy of this manual may be obtained by contacting the Ohio Department of Natural Resources, Division of Soil and Water Conservation, at (614) 265-6610.

Violators of ORC 6111 may be fined up to \$10,000 per day of violation. In addition, federal law allows for third party lawsuits for failure to comply with your NPDES permit.

Within fourteen (14) days of receipt of this letter, please submit to me at this office a written notification as to actions taken or proposed to eliminate violations of the permit. Your response should include the dates, either actual or proposed, for the completion of the actions. If you have any questions, please contact Aaron Wolfe at (740) 380-5277 or myself at (740) 380-5447.

Sincerely,

A handwritten signature in blue ink that reads "Clinton Kuenzli". The signature is written in a cursive, flowing style.

Clinton Kuenzli
Storm Water Section
Division of Surface Water

CDK/dh