



September 3, 2013

Steve Prater
Columbus Metropolitan Library
96 South Grant Avenue
Columbus, Ohio 43215

RE: Construction Storm Water Inspection at Columbus Metropolitan Library Driving Park Branch/ Franklin County, Permit Number: 4GC04216*AG

Dear Mr. Prater,

This letter is written regarding a storm water inspection conducted by Elizabeth Pleta of the Ohio EPA at Columbus Metropolitan Library Driving Park Branch located at 1422 East Livingston Avenue on August 1, 2013. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

Sediment and Erosion Control:

- At the time of inspection it appeared that the majority of the affected areas was contained within current excavation. Please be aware once an off-site grade is established, sediment controls are expected. This specifically applies to the south side of the site adjacent to East Livingston Avenue.
- Given the confined nature of the site, dewatering may be necessary. In accordance with the General Permit, all dewatering must be conducted in such a manner not to result in turbid discharges to waters of the state or an associated conveyance such as a road sided ditch or separate storm sewer system.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at harry.kallipolitis@epa.state.oh.us.

Sincerely

Harry Kallipolitis
Storm Water Coordinator
Ohio EPA
Division of Surface Water

c: Jeff Bohne, Water Quality Supervisor, DSW / CDO

HK/ste Columbus Metropolitan Library Driving Park Branch 7-31-13