



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

Re: **Notice of Violation**
Wood County
Five Point MHP WWTP
Ohio EPA Permit No. 2PY00073
NPDES Permit No. OH0141615

September 6, 2013

Mr. Trace Meyer, General Manager
Five Point Manufactured Home Community
24370 McCutcheonville Road
Perrysburg, Ohio 43551

Dear Mr. Meyer:

A review of the discharge monitoring reports that are submitted under the National Permit Discharge Elimination System (NPDES) permit for the Five Point Mobile Home Park (MHP) wastewater treatment plant (WWTP) shows that this facility is in significant noncompliance (SNC) for the following parameters at outfall number 001: Total Suspended Solids. I am enclosing a list of violations for this facility for the period of September 1, 2012, through September 1, 2013.

A facility becomes SNC when it exceeds the effluent limit for four or more months in two consecutive quarters or exceeds the effluent limit significantly in any two months in two consecutive quarters. Achieving compliance with Ohio's environmental laws is a primary focus of Ohio EPA in order to reduce risks to public health and welfare.

Before we initiate enforcement action, we would like to work with you to achieve satisfactory progress to bring this facility back into compliance. Within 21 days of the date of this letter, please submit, in writing, the actions that you propose to undertake in order to return your facility into compliance with your NPDES permit. You will also need to give us a timetable for these actions that does not extend past January 31, 2014. These actions and timetable may also be submitted by email to me at patricia.febbe@epa.ohio.gov.

If you wish to meet with us to discuss this matter, please contact me at 419-373-3016 within 10 days of receiving this letter in order to set up a meeting.

Mr. Trace Meyer
September 6, 2013
Page Two

I understand that you have owned this MHP since September 2012, and that you submitted paperwork to transfer the NPDES permit in your name. However that paperwork was not properly processed. I am enclosing a new form and instructions to transfer the NPDES permit. If you would please then mail or email the paperwork to me, I will make sure that the transfer is completed. I apologize for this inconvenience to you.

Sincerely,



Patricia A. Tebbe, P.E.
Division of Surface Water

/jlm

Enclosures

pc: Christina Faith

ec: Thomas Poffenbarger, DSW-NWDO
Tracking

Compliance Data for Five Point MHP between 9/1/2012 to 9/1/2013

Summary

Permit Effluent Limit Violations: 18

Permit Effluent Code Violations: 0

Compliance Schedule Milestones Not Entered: 0

Limit Violations						
Reporting Period	Station	Parameter	Limit Type	Limit	Reported Value	Violation Date
October 2012	001	Nitrogen, Ammonia (NH3)	30D Conc	1.5	26.5	10/1/2012
October 2012	001	Dissolved Oxygen	1D Conc	6.0	4.2	10/4/2012
October 2012	001	Dissolved Oxygen	1D Conc	6.0	4.	10/6/2012
October 2012	001	Dissolved Oxygen	1D Conc	6.0	4.1	10/8/2012
October 2012	001	Dissolved Oxygen	1D Conc	6.0	5.2	10/11/2012
October 2012	001	Dissolved Oxygen	1D Conc	6.0	4.3	10/17/2012
October 2012	001	Dissolved Oxygen	1D Conc	6.0	4.1	10/18/2012
October 2012	001	Dissolved Oxygen	1D Conc	6.0	5.3	10/25/2012
October 2012	001	Nitrogen, Ammonia (NH3)	1D Conc	2.2	26.5	10/25/2012
October 2012	001	Dissolved Oxygen	1D Conc	6.0	5.5	10/31/2012
November 2012	001	Total Suspended Solids	30D Conc	12.0	15.	11/1/2012
November 2012	001	Total Suspended Solids	30D Qty	0.3	.37472	11/1/2012
November 2012	001	Dissolved Oxygen	1D Conc	6.0	5.9	11/8/2012
February 2013	001	Total Suspended Solids	30D Conc	12.0	17.	2/1/2013
April 2013	001	Total Suspended Solids	30D Conc	12.0	16.	4/1/2013
June 2013	001	Total Suspended Solids	30D Conc	12.0	24.	6/1/2013
June 2013	001	Total Suspended Solids	1D Conc	18.0	24.	6/26/2013
July 2013	001	Total Suspended Solids	30D Conc	12.0	16.	7/1/2013