



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

August 17, 2012

Nick McGuire
Drummond Construction Inc.
201 Canal Street
Lancaster, Ohio 43130

**Re: Notice of Termination Inspection at Toxco Inc./Fairfield County
Permit #: 4GC03563*AG**

Dear Mr. McGuire:

This letter is written in follow up to a construction storm water inspection by Brittany Turner and Alicia Rector of the Ohio EPA conducted at Toxco Inc. located at 265 Quarry Road, Lancaster, Ohio on July 31, 2012. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, we noted the following:

It appeared during the inspection that construction activity has been completed for this site. A Notice of Termination will be required provided the post construction requirements are met. Please address the following:

- Please continue to monitor vegetation to ensure a successful vegetation cover to control erosion, measured by a minimum vegetation density of 70 percent. (See Figure 1)
- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction mandates can be found at: <http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx>. Please submit to my attention (email preferred at harry.kallipolitis@epa.state.oh.us) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria with your submittal.
- A Notice of Termination (NOT) must be submitted once the post construction and vegetative requirements are verified. The NOT form and filing instructions can be found at: <http://www.epa.state.oh.us/dsw/storm/stormform.aspx>.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office



Figure 1 70% Vegetation needed