



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

August 20, 2012

Shane Clark
Del-Co Water Company Inc.
6658 Olentangy River Road
Delaware, OH 43015

Re: **Storm Water Inspection at Lackey Old State Road Water Transmission Line 1/12 /
Delaware County Permit #: 4GC03796*AG**

Dear Mr. Clark:

This letter is written in follow-up to a construction storm water inspection I conducted at Lackey Old State Road Water Transmission Line 1/12 at Lackey Old State Road from Cheshire Road to US 36 on July 26, 2012. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with construction activities. During the inspection, I noted the following:

Sediment and Erosion Controls

- This inspection was conducted in follow up of an initial complaint investigation conducted by Greg Sanders a week prior to this inspection.
- I noted the installation of three (3) sediment bales for each culvert crossing. Please understand this fails to meet the minimum conditions of the General Storm Water Permit. Additional sediment controls are required to meet the minimum criteria of the General Permit. At this time I recommend immediate reclamation and/or the establishment of temporary stabilization efforts as an approvable acceptable alternative to sediment controls.
- At a minimum, straw check dams are expected every 200-300 feet to further reduce impacts to receiving streams in this area.

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844 or email at harry.kallipolitis@epa.state.oh.us. In addition, please provide a written response (**email preferred**) to the action items addressed above within ten days from receipt of this letter. A follow-up inspection will be conducted to ensure the minimum conditions of the General Permit have been met.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office