



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

September 5, 2013

RE: WILDWOOD LAKES CAMPGROUND
PERMIT NO. 3GS00018
MEDINA COUNTY
HOMER TOWNSHIP

Mr. Jim Emmert
WildWood Lakes Campground
11450 Crawford Road
Homerville, Ohio 44235

Dear Mr. Emmert:

On August 8, 2013, an inspection of the above referenced facility's wastewater treatment system was conducted. The facility was represented by you. The purpose of the inspection was to evaluate the operation and maintenance of the treatment plant along with the facility's compliance status with respect to the terms and conditions of the above referenced National Pollutant Discharge Elimination System (NPDES) permit.

During the inspection, the following items were noted/discussed:

1. The campground is open during the months of May through September.
2. During winter, you indicated that the plant is aerated one hour three times per 24 hour period.
3. The plant design of the wastewater treatment system is 5,000 gpd with a 5,000 gallon flow equalization tank.
4. Wood fencing was installed around the perimeters of the treatment plant and the sand filter cells since the last inspection.
5. An in-ground pool has also been installed since the last inspection. You indicated that the pool filter backwash water is routed to the campground wastewater treatment plant's dosing chamber. The backwash is then pumped to the sand filter cells, chlorinated, and de-chlorinated prior to being discharged. The backwash is approximately 200 gallons per day. You indicated that Mr. Chuck Allen of this office approved this connection.
6. You indicated that Mr. Richard Smith and Mr. Victor Reverendo from Ohio EPA's Compliance and Assistance group visited your campground in mid 2012 to assist you in the day to day technical operations of the waste water treatment plant. Since their visit, you indicated that you have a much better understanding of the daily operations of the treatment plant.
7. In accordance with Ohio Administrative Code 3745-7-04, the sewage treatment facility is classified as a Class A facility. The classification requires that the Operator of Record be physically present at the treatment works two days per week for a minimum of one hour per week.
8. Ohio EPA has on record that you are the current Operator of Record. The date of notification on record is November 24, 2009. Ohio EPA's records also indicate that you hold a Limited Class "A" Wastewater Operator's License.
9. Ohio operator certification rules require that a field log book be maintained at the

WILDWOOD LAKES CAMPGROUND
 SEPTEMBER 5, 2013
 PAGE 3 OF 3

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	80082	CBOD 5 day	7D Conc	15	22.4	6/8/2011
001	00530	Total Suspended Solids	30D Conc	12	23.	8/1/2011
001	00530	Total Suspended Solids	7D Conc	18	23.	8/15/2011
001	00610	Nitrogen, Ammonia (NH3)	30D Conc	1.0	1.34	8/1/2011
001	80082	CBOD 5 day	30D Conc	10	34.	8/1/2011
001	80082	CBOD 5 day	7D Conc	15	34.	8/15/2011
001	00530	Total Suspended Solids	30D Conc	12	15.	6/1/2012
001	80082	CBOD 5 day	30D Conc	10	22.6	6/1/2012
001	80082	CBOD 5 day	7D Conc	15	22.6	6/8/2012
001	00300	Dissolved Oxygen	1D Conc	6.0	.	8/1/2012
001	00300	Dissolved Oxygen	1D Conc	6.0	.	8/2/2012
001	00300	Dissolved Oxygen	1D Conc	6.0	.	8/3/2012
001	00300	Dissolved Oxygen	1D Conc	6.0	.	8/4/2012
001	00300	Dissolved Oxygen	1D Conc	6.0	.	8/5/2012
001	00300	Dissolved Oxygen	1D Conc	6.0	.	8/6/2012
001	00300	Dissolved Oxygen	1D Conc	6.0	.	8/7/2012
001	00300	Dissolved Oxygen	1D Conc	6.0	.	8/8/2012
001	00300	Dissolved Oxygen	1D Conc	6.0	.	8/9/2012
001	00300	Dissolved Oxygen	1D Conc	6.0	.	8/10/2012
001	00300	Dissolved Oxygen	1D Conc	6.0	.	8/11/2012
001	00300	Dissolved Oxygen	1D Conc	6.0	.	8/12/2012
001	00300	Dissolved Oxygen	1D Conc	6.0	.	8/13/2012
001	00300	Dissolved Oxygen	1D Conc	6.0	.	8/14/2012
001	00300	Dissolved Oxygen	1D Conc	6.0	.	8/15/2012
001	00300	Dissolved Oxygen	1D Conc	6.0	.	8/16/2012
001	00300	Dissolved Oxygen	1D Conc	6.0	.	8/17/2012
001	00300	Dissolved Oxygen	1D Conc	6.0	.	8/18/2012
001	00300	Dissolved Oxygen	1D Conc	6.0	.	8/19/2012
001	00300	Dissolved Oxygen	1D Conc	6.0	.	8/20/2012
001	00300	Dissolved Oxygen	1D Conc	6.0	.	8/21/2012
001	00300	Dissolved Oxygen	1D Conc	6.0	.	8/22/2012
001	00300	Dissolved Oxygen	1D Conc	6.0	.	8/23/2012
001	00300	Dissolved Oxygen	1D Conc	6.0	.	8/24/2012
001	00300	Dissolved Oxygen	1D Conc	6.0	.	8/25/2012
001	00300	Dissolved Oxygen	1D Conc	6.0	.	8/26/2012
001	00300	Dissolved Oxygen	1D Conc	6.0	.	8/27/2012
001	00300	Dissolved Oxygen	1D Conc	6.0	.	8/28/2012
001	00300	Dissolved Oxygen	1D Conc	6.0	.	8/29/2012
001	00300	Dissolved Oxygen	1D Conc	6.0	.	8/30/2012
001	00300	Dissolved Oxygen	1D Conc	6.0	.	8/31/2012
001	80082	CBOD 5 day	30D Conc	10	12.	8/1/2012
001	50060	Chlorine, Total Residue	1D Conc	0.019	.05	6/8/2013

Please be advised that such instances of noncompliance in reporting requirements may be cause for enforcement actions pursuant to the Ohio Revised Code, Chapter 6111.

WILDWOOD LAKES CAMPGROUND
SEPTEMBER 5, 2013
PAGE 4 OF 4

Should you have any comments or questions concerning this letter, please feel free to call me at (330) 963-1143.

Respectfully,

A handwritten signature in black ink that reads "Michael W. Stevens". The signature is written in a cursive style with a large initial "M".

Michael W. Stevens
Environmental Engineer
Division of Surface Water

MWS/cs