



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

September 11, 2013

Re: Scioto County
Southern Ohio Correctional Facility
Lucasville WWTP
Self-Monitoring Report Violations
Ohio EPA Permit OPP00078*ED

Southern Ohio Correctional Facility
Lucasville WWTP
22 Cook Road
Lucasville, OH 45648

We have received your self-monitoring reports covering the months of **May and June 2013** for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Station	Type	Date	Reporting Code	Parameter	Limit Type	Permit Limit	Reported Value
May 2013:							
001	Limit	5/23/2013	00300	Dissolved Oxygen	Daily Conc.	6.0	5.9
June 2013:							
001	Limit	6/17/2013	61942	pH, Minimum	Daily Conc.	6.5	6.1

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.


Please inform this office, in writing, within ten days of receipt of this notification as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions.

The Ohio EPA strongly encourages pollution prevention as the preferred approach for waste management. The first priority of pollution prevention is to eliminate the generation of wastes and pollutants at the source (source reduction). For those wastes or pollutants that are generated, the second priority is to recycle or reuse them in an environmentally sound manner. You can benefit economically, help preserve the

environment, and improve your public image by implementing pollution prevention programs. For more information about pollution prevention, including fact sheets and U.S. EPA's Facility Pollution Prevention Guide, (EPA/600/R-92/088), you may contact the Ohio EPA Pollution Prevention Section at (614) 644-3469 or me for additional information.

If there are any questions, please contact this office.

Sincerely,



Scott Foster
Environmental Specialist 2
Division of Surface Water

SF/dh